Name_____ ECE 3600 homework 10 Due: Sat, 9/28/24

- 1. A 3-phase system operates at 200 kVA and 10 kV. Using these quantities as base values, find:
 - a) The base current and base impedance for the system.

Use these bases below:

b) Express the following as a per-unit values

$$V_L := 8 \cdot kV$$

$$I_{I} := 12 \cdot A$$

$$I_{\mathbf{I}} := (5+2j) \cdot A$$

$$P = 40 \cdot kW$$

$$Q_{1\phi} = 20 \cdot kVAR$$

$$\mathbf{Z} = 1.2 \cdot k\Omega \cdot e^{-j \cdot 10 \cdot deg}$$

- c) The line voltage represented by $~V_{pu} \coloneqq 0.98 \cdot pu$
- d) The line-to-neutral voltage represented by $V_{pu} := 1.04 \cdot pu$
- e) The real power represented by $P_{pu} := 0.3 \cdot pu$
- f) The single-phase power represented by $P_{pu} := 0.3 \cdot pu$
- g) The single-phase reactive power represented by $\mathbf{S}_{\,\boldsymbol{pu}} \coloneqq 0.4 \cdot e^{j \cdot 14 \cdot deg} \cdot pu$
- h) The line current represented by $~\mathbf{I}_{~\bm{pu}} \coloneqq (0.5 + 0.2j) \cdot pu$
- i) The impedance represented by $~\mathbf{Z}_{~\boldsymbol{pu}} \coloneqq 2.8 \cdot pu \cdot e^{j \cdot 24 \cdot deg}$

ECE 3600 homework 10 p2

2. If $26.1~\Omega$ is the impedance base and 124~A is the current base for a 3-phase system, find the power base and voltage base.

3. A 3-phase transmission line supplies a reactive load at a lagging power factor. The load draws $0.5~\rm pu$ current at $1.0~\rm pu$ voltage while using $0.4~\rm pu$ real power. If the base voltage is $20~\rm kV$ and the base current is $16~\rm A$, calculate the power factor and the values of the resistance and reactance of the load. Give both the pu and Ω .

```
Answers 1. a) 11.6 \cdot A 500 \cdot \Omega
```

b) 0.8·pu 1.039·pu (0.433 + 0.173·j)·pu 0.2·pu 0.3·pu (2.364 - 0.417·j)·pu c) 9.8·kV d) 6·kV e) 60·kW f) 20·kW g) 6.45·kVAR h) (5.77 + 2.31j)·A i) (1.28 + 0.57j)·kΩ 2. 1.2·MVA 5.61·kV

3. 80-% If R & X are in parallel 2.5·pu 1.804·kΩ 3.333·pu 2.406·kΩ If R & X are in series 1.6·pu 1.155·kΩ 1.2·pu 0.866·kΩ **ECE 3600 homework 10 p2**